



NATIONAL TERRAZZO & MOSAIC ASSOCIATION

www.ntma.com

800.323.9736

Technical Bulletin G-28

9/13

Finish of Terrazzo

Unless specified otherwise, the standard finish is a #80 or #120 silicon carbide stone or diamond equivalent to generally match approved mock-up installation area and samples.

Small areas and internal corners of terrazzo that cannot be readily reached and ground with the conventional production equipment must utilize specialty hand tools to uniformly expose the aggregate. Areas that will not allow for the use of hand tools due to space restrictions should be precast.

Areas that will not be visible when the building is complete may not be finished. Such as areas as under column covers or baseboards may be left in the unfinished state

Note: All evaluations are to be made looking straight down from a standing position without extraordinary magnification.

Terrazzo is an in situ created product by human craftsmanship and the installer must endeavor to meet the standards for the entire project. However, the terrazzo should not be arbitrarily rejected for relatively minor non-compliance. This is especially true if the overall functional and aesthetic values were satisfied.

General Disclaimer: *The information provided in the Technical Bulletin is for general informational purposes only. Each project and individual application are unique. All information is provided in good faith: However, NTMA makes no representations or warranties of any kind, express or implied, regarding the accuracy, adequacy, validity, reliability, or completeness of any information provided herein.*